

Round 1: 2/4/2017

Sample	School	Code	Location	Results (ppb)
1	Lambertville	Field Blank	Field Blank	ND
<b>2</b>	<b>Lambertville</b>	<b>LAM-POE</b>	<b>Across from LAM-WF-01</b>	<b>320</b>
3	Lambertville	LAM-POE F	Across from LAM-WF-01	2.6
4	Lambertville	LAM-WF-01	Hallway BR	5.4
<b>5</b>	<b>Lambertville</b>	<b>LAM-WF-01 F</b>	<b>Hallway BR</b>	<b>54</b>
6	Lambertville	LAM-WF-02	Hallway BR	10
7	Lambertville	LAM-WF-02 F	Hallway BR	11
8	Lambertville	LAM-WF-03	Hallway Across 18	0.8
9	Lambertville	LAM-WF-03 F	Hallway Across 18	1.4
10	Lambertville	LAM-S-04	Room 18	2.3
11	Lambertville	LAM-S-04 F	Room 18	1.8
12	Lambertville	LAM-S-05	Kitchen	10
13	Lambertville	LAM-S-05 F	Kitchen	1.9
14	Lambertville	LAM-S-06	Kitchen	6.0
<b>15</b>	<b>Lambertville</b>	<b>LAM-S-06 F</b>	<b>Kitchen</b>	<b>44</b>
16	Lambertville	LAM-S-07	Kitchen	6.9
17	Lambertville	LAM-S-07 F	Kitchen	5.3
18	Lambertville	LAM-S-08	Nurse	10
19	Lambertville	LAM-S-08 F	Nurse	1.3
20	Lambertville	LAM-S-09	Faculty Lounge (FL)	8.1
21	Lambertville	LAM-S-09 F	Faculty Lounge (FL)	3.0
22	Lambertville	LAM-WF-10	Hallway near FL	2.6
23	Lambertville	LAM-WF-10 F	Hallway near FL	1.1
24	Lambertville	LAM-WF-11	Hallway near FL	4.1

Sample	School	Code	Location	Results (ppb)
25	Lambertville	LAM-WF-11 F	Hallway near FL	0.7
26	Lambertville	LAM-WF-12	Hallway near FL	6.8
27	Lambertville	LAM-WF-12 F	Hallway near FL	0.82
28	Lambertville	LAM-S-13	BR in RM 11	ND
29	Lambertville	LAM-S-13 F	BR in RM 11	ND
30	Lambertville	LAM-WF-14	Room 8	14
31	Lambertville	LAM-WF-14 F	Room 8	7.2
<b>32</b>	<b>Lambertville</b>	<b>LAM-WF-15</b>	<b>Room 7</b>	<b>16</b>
33	Lambertville	LAM-WF-15 F	Room 7	7.1
34	Lambertville	LAM-WF-16	Across RM 3	1.1
35	Lambertville	LAM-WF-16 F	Across RM 3	1.3
36	Lambertville	LAM-WF-17	Across RM 3	4.4
37	Lambertville	LAM-WF-17 F	Across RM 3	10
38	South Hunterdon	Field Blank	Field Blank	ND
39	South Hunterdon	SHHS-POE	Pump Room	6.9
40	South Hunterdon	SHHS-POE F	Pump Room	0.89
41	South Hunterdon	SHHS-WF-01	Cafeteria	2.0
42	South Hunterdon	SHHS-WF-01 F	Cafeteria	3.2
43	South Hunterdon	SHHS-S-02	Kitchen	3.8
44	South Hunterdon	SHHS-S-02 F	Kitchen	0.78
45	South Hunterdon	SHHS-WF-03	Hallway outside gym	1.2
46	South Hunterdon	SHHS-WF-03 F	Hallway outside gym	2.1
47	South Hunterdon	SHHS-WF-04	Hallway across MS gym	2.6

Sample	School	Code	Location	Results (ppb)
48	South Hunterdon	SHHS-WF-04 F	Hallway across MS gym	3.1
49	South Hunterdon	SHHS-WF-05	MS Commons	ND
50	South Hunterdon	SHHS-WF-05 F	MS Commons	ND
51	South Hunterdon	SHHS-WF-06	MS Commons	ND
52	South Hunterdon	SHHS-WF-06 F	MS Commons	ND
53	South Hunterdon	SHHS-WF-07	MS Hallway	ND
54	South Hunterdon	SHHS-WF-07 F	MS Hallway	0.51
55	South Hunterdon	SHHS-WF-08	H10	4.4
56	South Hunterdon	SHHS-WF-08 F	H10	0.52
57	South Hunterdon	SHHS-WF-09	Hallway Across A101	1.4
58	South Hunterdon	SHHS-WF-10	Hallway Across C104	8.7
59	South Hunterdon	SHHS-WF-10 F	Hallway Across C104	6.9
60	South Hunterdon	SHHS-S-11	C-105	6.9
61	South Hunterdon	SHHS-S-12	C-105	3.4
62	South Hunterdon	SHHS-S-13	C-105	8.4
63	South Hunterdon	SHHS-S-14	C-105	6.0
64	South Hunterdon	SHHS-S-15	C-105	7.9
65	South Hunterdon	SHHS-S-16	C-105	9.9
66	South Hunterdon	SHHS-S-17	C-107	ND
67	South Hunterdon	SHHS-WF-18	Hallway across C-102	ND
68	South Hunterdon	SHHS-S-19	Lounge	5.1

Sample	School	Code	Location	Results (ppb)
69	South Hunterdon	SHHS-S-20	Lounge	5.3
70	South Hunterdon	SHHS-S-21	Nurse	1.8
71	South Hunterdon	SHHS-WF-22	Hallway Auditorium	0.51
72	South Hunterdon	SHHS-WF-23	Hallway Auditorium	0.59
73	South Hunterdon	SHHS-S-24	Outside Auditorium	0.76
74	South Hunterdon	SHHS-S-25	Main Office Kitchen	8.7
75	South Hunterdon	SHHS-IM-26	Ice Machine in Kitchen	ND
76	South Hunterdon	SHHS-S-27	C-109	4.2
77	Stockton Borough	Field Blank	Field Blank	ND
78	Stockton Borough	SBS-POE	Main Office BR Sink	2.3
79	Stockton Borough	SBS-WF-01	Main Office	2.6
80	Stockton Borough	SBS-WF-02	Hallway near Entrance	0.66
81	Stockton Borough	SBS-WF-03	Classroom grades 1/2	6.3
82	Stockton Borough	SBS-S-04	Kitchenette	1.1
83	West Amwell	Field Blank	Field Blank	ND
84	West Amwell	WAS-POE	Boiler Room	10
85	West Amwell	WAS-POE F	Boiler Room	1.7
86	West Amwell	WAS-WF-01	Across Office	ND
87	West Amwell	WAS-WF-01 F	Across Office	ND
88	West Amwell	WAS-WF-02	Across Office	ND
89	West Amwell	WAS-WF-02 F	Across Office	ND
90	West Amwell	WAS-WF-03	Next to 107	ND
91	West Amwell	WAS-WF-03 F	Next to 107	ND

Sample	School	Code	Location	Results (ppb)
92	West Amwell	WAS-WF-04	Room 104	2.1
93	West Amwell	WAS-WF-04 F	Room 104	2.9
94	West Amwell	WAS-WF-05	Room 103	1.9
95	West Amwell	WAS-WF-05 F	Room 103	4.3
96	West Amwell	WAS-WF-06	Room 112	1.8
97	West Amwell	WAS-WF-06 F	Room 112	1.7
98	West Amwell	WAS-WF-07	Room 111	1.9
99	West Amwell	WAS-WF-07 F	Room 111	1.9
100	West Amwell	WAS-WF-08	Room 113	4.9
101	West Amwell	WAS-WF-08 F	Room 113	1.8
<b>102</b>	<b>West Amwell</b>	<b>WAS-WF-09</b>	<b>Room 115</b>	<b>18</b>
103	West Amwell	WAS-WF-09 F	Room 115	4.2
104	West Amwell	WAS-WF-10	Room 116	1.2
105	West Amwell	WAS-WF-10 F	Room 116	1.3
106	West Amwell	WAS-WF-11	Room 114	2.9
107	West Amwell	WAS-WF-11 F	Room 114	2.5
<b>108</b>	<b>West Amwell</b>	<b>WAS-S-12</b>	<b>Nurse</b>	<b>15</b>
109	West Amwell	WAS-S-12 F	Nurse	4.2
110	West Amwell	WAS-S-13	Kitchen	7.7
111	West Amwell	WAS-S-13 F	Kitchen	1.7

Sample	School	Code	Location	Results (ppb)
112	West Amwell	WAS-S-14	Kitchen in White house	6.4
113	West Amwell	WAS-S-14 F	Kitchen in White house	0.84

Round 2: 2/21/2017

Sample	School	Code	Location	Results (ppb)
1	Lambertville	Field Blank	Field Blank	ND
<b>2</b>	<b>Lambertville</b>	<b>LAM-POE</b>	<b>Across from LAM-WF-01</b>	<b>23</b>
3	Lambertville	LAM-POE F	Across from LAM-WF-01	1.8
<b>4</b>	<b>Lambertville</b>	<b>LAM-S-05</b>	<b>Kitchen</b>	<b>180</b>
5	Lambertville	LAM-S-05 F	Kitchen	8.4
<b>6</b>	<b>Lambertville</b>	<b>LAM-S-06</b>	<b>Kitchen</b>	<b>40</b>
7	Lambertville	LAM-S-06 F	Kitchen	11
<b>8</b>	<b>Lambertville</b>	<b>LAM-S-07</b>	<b>Kitchen</b>	<b>270</b>
9	Lambertville	LAM-S-07 F	Kitchen	6.3
<b>10</b>	<b>Lambertville</b>	<b>LAM-WF-15</b>	<b>Room 7</b>	<b>160</b>
11	Lambertville	LAM-WF-15 F	Room 7	15

Round 3: 2/24/2017

Sample	School	Code	Location	Results (ppb)
1	Lambertville	Field Blank	Field Blank	ND
<b>2</b>	<b>Lambertville</b>	<b>LAM-POE</b>	<b>Across from LAM-WF-01</b>	<b>18</b>
3	Lambertville	LAM-POE F	Across from LAM-WF-01	1.1
4	Lambertville	LAM-WF-01	Hallway BR	10
<b>5</b>	<b>Lambertville</b>	<b>LAM-WF-01 F</b>	<b>Hallway BR</b>	<b>72</b>
<b>6</b>	<b>Lambertville</b>	<b>LAM-WF-02</b>	<b>Hallway BR</b>	<b>15</b>

Sample	School	Code	Location	Results (ppb)
<b>7</b>	<b>Lambertville</b>	<b>LAM-WF-02 F</b>	<b>Hallway BR</b>	<b>15</b>
8	Lambertville	LAM-WF-03	Hallway Across 18	0.55
9	Lambertville	LAM-WF-03 F	Hallway Across 18	1.2
10	Lambertville	LAM-S-04	Room 18	3.3
11	Lambertville	LAM-S-04 F	Room 18	5.5
12	Lambertville	LAM-S-05	Kitchen	2.8
13	Lambertville	LAM-S-05 F	Kitchen	4.3
14	Lambertville	LAM-S-06	Kitchen	7.9
15	Lambertville	LAM-S-06 F	Kitchen	3.5
<b>16</b>	<b>Lambertville</b>	<b>LAM-S-07</b>	<b>Kitchen</b>	<b>28</b>
17	Lambertville	LAM-S-07 F	Kitchen	3.7
18	Lambertville	LAM-S-08	Nurse	9.2
19	Lambertville	LAM-S-08 F	Nurse	1.2
20	Lambertville	LAM-S-09	Faculty Lounge (FL)	4.4
21	Lambertville	LAM-S-09 F	Faculty Lounge (FL)	1.4
22	Lambertville	LAM-WF-10	Hallway near FL	3.6
23	Lambertville	LAM-WF-10 F	Hallway near FL	1.3
24	Lambertville	LAM-WF-11	Hallway near FL	3.4
25	Lambertville	LAM-WF-11 F	Hallway near FL	0.86
26	Lambertville	LAM-WF-12	Hallway near FL	6.8
27	Lambertville	LAM-WF-12 F	Hallway near FL	1.0
28	Lambertville	LAM-S-13	BR in RM 11	ND
29	Lambertville	LAM-S-13 F	BR in RM 11	ND
30	Lambertville	LAM-WF-14	Room 8	13

Sample	School	Code	Location	Results (ppb)
31	Lambertville	LAM-WF-14 F	Room 8	5.8
<b>32</b>	<b>Lambertville</b>	<b>LAM-WF-15</b>	<b>Room 7</b>	<b>42</b>
33	Lambertville	LAM-WF-15 F	Room 7	5.6
34	Lambertville	LAM-WF-16	Across RM 3	0.86
35	Lambertville	LAM-WF-16 F	Across RM 3	1.2
36	Lambertville	LAM-WF-17	Across RM 3	2.4
37	Lambertville	LAM-WF-17 F	Across RM 3	2.4

Round 4: 3/24/2017

Sample	School	Code	Location	Results (ppb)
1	Lambertville	Field Blank	Field Blank	ND
2	Lambertville	LAM-WF-03	Hallway Across 18	ND
3	Lambertville	LAM-WF-03 F	Hallway Across 18	ND
<b>4</b>	<b>Lambertville</b>	<b>LAM-S-07</b>	<b>Kitchen</b>	<b>54.2</b>
5	Lambertville	LAM-S-07 F	Kitchen	0.567
6	Lambertville	LAM-WF-10	Hallway near FL	ND
7	Lambertville	LAM-WF-10 F	Hallway near FL	ND
8	Lambertville	LAM-WF-11	Hallway near FL	ND
9	Lambertville	LAM-WF-11 F	Hallway near FL	ND
10	Lambertville	LAM-BF-12	Hallway near FL	ND
11	Lambertville	LAM-BF-12 F	Hallway near FL	ND
12	Lambertville	LAM-WF-16	Across RM 3	ND
13	Lambertville	LAM-WF-16 F	Across RM 3	ND
14	Lambertville	LAM-WF-17	Across RM 3	ND
15	Lambertville	LAM-WF-17 F	Across RM 3	ND



Sample	School	Code	Location	Results (ppb)
16	Lambertville	LAM-BF-19	Across RM 2	ND
17	Lambertville	LAM-BF-19 F	Across RM 2	ND
18	Lambertville	LAM-WF-20	Hallway Across 18	ND
19	Lambertville	LAM-WF-20 F	Hallway Across 18	ND
20	Lambertville	LAM-BF-21	Hallway Across 18	ND
21	Lambertville	LAM-BF-21 F	Hallway Across 18	ND

Round 5: 4/28/2017

Sample	School	Code	Location	Results (ppb)
1	Lambertville	Field Blank	Field Blank	ND
<b>2</b>	<b>Lambertville</b>	<b>LAM-S-07</b>	<b>Kitchen</b>	<b>23.8</b>
3	Lambertville	LAM-S-07 F	Kitchen	0.598

Round 6: 5/12/2017

Sample	School	Code	Location	Results (ppb)
1	Lambertville	Field Blank	Field Blank	ND
2	Lambertville	LAM-S-07	Kitchen	5.59
3	Lambertville	LAM-S-07 F	Kitchen	ND